

## Test Verification of Conformity

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.

**Applicant Name & Address** : CHINT EUROPE (UK) LTD  
Units 9 & 11, Spark Business Park, Hamilton Road,  
Stockport, Manchester, SK1 2AE, United Kingdom

**Product(s) Tested** : Fused connection unit

**Ratings and principal characteristics** : 13A 250V~, flush type, IP20, rewirable, with pillar terminals, with 13A fuse, with or without double-pole rocker switch, with or without neon, with or without flex outlet, with plastic or metal cover, details see annex.

**Model(s)** : ST2130, ST2131, ST2136, ST2137, ST2132, ST2133, ST2134, ST2135, SLM-2130, SLM-2131, SLM-2136, SLM-2137, SLM-2132, SLM-2133, SLM-2134, SLM-2135 (total 16 models)

**Brand name** : **SHELD**

**Relevant Standard(s)/Specification(s)** : BS 1363-4: 1995 + A4: 2012


**Verification Issuing Office Name & Address** : Intertek Testing Services Shanghai  
Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China

**Verification Number** : 160100977SHA-V1

**Report Number(s)** : 140801073SHA-001+A1

**NOTE: This verification is part of the full test report(s) and should be read in conjunction with it.**

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Oliver Wei  
Manager  
February 23, 2016

## Annex to Test Verification of Conformity

This is an Annex to Test Verification of Conformity with 160100977SHA-V1. The issuing office is Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China

### Difference between models:

No.	Model name	Description
1	ST2130	13A unswitched connection unit, with plastic cover.
2	ST2131	13A unswitched connection unit, with neon, with plastic cover.
3	ST2136	13A unswitched connection unit, with flex outlet, with plastic cover.
4	ST2137	13A unswitched connection unit, with flex outlet, with neon, with plastic cover.
5	ST2132	13A switched connection unit, with plastic cover.
6	ST2133	13A switched connection unit, with neon, with plastic cover.
7	ST2134	13A switched connection unit, with flex outlet, with neon, with plastic cover.
8	ST2135	13A switched connection unit, with flex outlet, with plastic cover.
9	SLM-2130	13A unswitched connection unit, with metal cover.
10	SLM-2131	13A unswitched connection unit, with neon, with metal cover.
11	SLM-2136	13A unswitched connection unit, with flex outlet, with metal cover.
12	SLM-2137	13A unswitched connection unit, with flex outlet, with neon, with metal cover.
13	SLM-2132	13A switched connection unit, with metal cover.
14	SLM-2133	13A switched connection unit, with neon, with metal cover.
15	SLM-2134	13A switched connection unit, with flex outlet, with neon, with metal cover.
16	SLM-2135	13A switched connection unit, with flex outlet, with metal cover.

**NOTE: This verification is part of the full test report(s) and should be read in conjunction with it.**

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Oliver Wei  
Manager  
February 23, 2016