


Certificate



Reference No. 607783

Circuit-breakers for overcurrent protection

Type designation NBH8-40H

Certificate holder Zhejiang Chint Electrics Co., Ltd.
Chint High-tech Industrial Zone
North Baixiang 325603
Wenzhou, Zhejiang
CHINA

The product complies with the standard(s) EN 60898-1:2003+A1+A11

Date of expiry 14 August 2011

EU Directive information The product satisfies the provisions for CE marking according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Terms in Intertek Semko's Agreement on certification. Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed 
Alve Nilsson *Date* 8 August 2006

STE



Appendix

Reference No. 607783

Technical data


| | |
|-----------------------|---|
| Type designation/ | NBH8-40H |
| Brand name: | CHNT |
| Rated Voltage (V) / | 240 |
| Rated Current (A) / | 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40 |
| Frequency (Hz) / | 50/60 |
| IP-class / | 20 |
| Poles No. / | 1P+N |
| Product information / | $I_{cs} = I_{cn} = 6000A$, B- and C-Type |

Manufacturing site(s) Zhejiang Chint Electrics Co., Ltd.
Chint High-tech Industrial Zone
North Baixiang 325603
Wenzhou, Zhejiang
CHINA

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed



Alve Nilsson

Date 8 August 2006

STE