

C E R T I F I C A T E



of Conformity Low Voltage Directive 2006/95/EC

Registration No.: AN 50230750 0001

Report No.: 15053024 001

Holder: Zhejiang Chint Electrics Co., Ltd.
No.1,
Chint Road,Chint Industrial Zone,
North Baixiang
Yueqing, Zhejiang Province 325603
P.R. China

Product: Thermal Overload Relay
(Phase Loss Sensitive Thermal Overload Relay)

Identification: Type Designation : NR2-11,5
Ratings : 3-pole;Ith:13A;Class 10A
0,1-0,16A/0,16-0,25A/0,25-0,4A/0,4-0,63A
0,63-1A/1-1,6A/1,25-2A/1,6-2,5A/2,5-4A
4-6A/5,5-8A/7-10A/9-13A
Serial No. : Engineering samples
Remark: 1) Test acc. to EN 60947-4-1:2010
2) Refer to test report 15053024 001 for details.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with all revision of Annex I of Council Directive 2006/95/EC, in its latest amended version, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex III of the Directive.



Certification Body

Date 19.09.2012

Jie Zhang

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE